CHAPTER - 2

SALIENT FEATURES

1. LOCATION

(i) Location Diversion site: Near village Singoli

Power Station: Near Village Phalai

(ii) District - Rudraprayag

(iii) Tehsil - Okhimath

(iv) Diversion Site

Latitude - 30° 30′ 17″ N Longitude - 79° 05′ 22″ E

(v) Power House Site

Latitude - 30° 24' 11" N Longitude - 79° 02' 25" E

(vi) River - Mandakini

2. HYDROLOGY

(i) Total catchment area 650 sq. km.(ii) Snow bound catchment 294 sq. km.

3. DESIGN FLOOD DISCHARGE

(i) Design Flood Discharge

1 to 100 year frequency 1284 Cumecs

(ii) Design Flood Discharge

1 to 1000 year frequency 1709 Cumecs

4. DIVERSION BARRAGE

(i) River bed level at barrage site 1005 m(ii) High Flood Level 1010 m

(iii) Type of diversion Gated barrage 68 m long with 5 bays of

12 m each

(iv) Intake structure Head Regulator of 2 spans of 8 m each

5. SEDIMENTATION TANK

(i) Size 140 x 18 x 10 m approx.

(ii) Design discharge for flushing

Lean period (November-March) 1.0 cumec

Rest of year 3.0-5.0 cumec

6. POWER TUNNEL

(i) Shape Horse shoe (ii) Diameter 3.5 m

(iii) Length 12.5 km

(iv) Number of adits 3

(v) Design discharge 40 cumecs

7. SURGE TANK

(i) Type Restricted Orifice

(ii) Diameter 12 m (approx.)

8. PENSTOCK

(i) Main Penstock One No. 2.80 dia.

(ii) Unit Penstock 3 nos. branching off the main

penstock

9. POWER HOUSE

(i) Location Near village Phalai

(ii) Type Surface(iii) Maximum Gross Head 210.0 m

(iv) Installed capacity 60 MW (3 x 20 MW)

(v) Type of turbine Francis

10. TAIL RACE

(i) Type Trapezoidal

(ii) Bottom width 10.0 m

(iii) Length 100 m

11. ANNUAL ELECTRICAL ENERGY

Gross Annual Generation

(i)	During 90% dependability year	354.94 MU
(ii)	During 75% dependability year	372.96 MU
(iii)	During 60% dependability year	394.34 MU
(iv)	During 50% dependability year	400.30 MU